



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT :SOUTH ZONE
GREEN PARK, AUROBINDO MARG NEW DELHI 110016

No: DHO/SZ/2022/ D 1935

Dated19.9.2022

SCHOOL HEALTH CERTIFICATE

1. Name of the Schools- St. Paul's School
2. School Address Phase -VI, H-Block, Aya Nagar, New Delhi- 110047
3. No. of Shift - One, Timing - 7:40 AM to 2:00 PM
4. No. of Students: Boys - 799 , Girls - 604 ,Total - 1403
5. No. of Staffs: Male -08 , Female - 50 , Total- 58

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient - Sufficient
2. The Classrooms are Well Lighted/ ill lighted- Well Lighted
3. The Classrooms are Well Ventilated/ ill ventilated - Well Ventilated
4. The Classrooms are kept / Not'kept Neat & Clean - Neat and Clean
5. The Classrooms/Building requires/ do not required Whitewash etc.- Not required
6. The Drinking Water is Wholesome/ not wholesome -Wholesome
7. The Latrine arrangement is Sanitary/ insanitary- Sanitary

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is Sufficient
2. One latrine for 40 male student is required so total is Sufficient
3. Separate Toilet arrangement for staff present: Yes/No Yes
4. The Overall facilities: Good/ Adequate/Inadequate Adequate from Health Point of View & Valid upto one year from issuance date.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

P.T. Bonadelle
Principal
St. Paul's School
Phase-VI, H-Block,
Aya Nagar, New Delhi-47

J. Sharma
CHAIRMAN
ST. PAUL'S SCHOOL
Phase-VI, H Block
Aya Nagar, New Delhi-110074

Sanjay
Deputy Health Officer
South Zone
Dy. Health Officer/SZ



ITS LABORATORY

Laboratory: 10/81, Sector-40, Phase-2, Noida, Distt. Gautam Buddha Nagar - 201301, (I.P.)
M. 9951632934, 9166780112, 9952240164, 9951282834
Website: www.itslab.in, Email: contact@itslab.in, info@itslab.in, itslab@itslab.com
ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory

Report Code: W-270822-03 Page 1 of 2

TEST REPORT

Water Test Report

Report Code: W-270822-03

Issue Date: 31/08/2022

Issued To: St. Paul's School
Address: Phase-VI, H-Block, Aya Nagar, New Delhi-110047

SAMPLING & ANALYSIS DATA

Sample Received On : 27/08/2022
Sample Drawn By : Mr. Amardeep (ITS)
Sample Description : Drinking Water
Sample Drawn On : 27/08/2022
Sample Quantity : 1.0 Liter for chemical & 500ml for microbiological in glass bottle
Analysis Duration : 27/08/2022 TO 31/08/2022

DRINKING WATER

Essential test as per IS:10500-2012

Parameter	Test Method	Results	Units	Desirable Limit	Extended Limit
pH	IS-3025(Part-11)	6.66		6.5 - 8.5	
Colour	IS-3025(Part-4)	<5.0	Hazen	5	25
Turbidity	IS-3025(Part-10)	<1.0	NTU	5.0	10
Total Hardness (as CaCO ₃)	IS-3025(Part-21)	38.07	mg/l	200	500
Chloride (as Cl)	IS-3025(Part-32)	14.0	mg/l	250	1000
Calcium (as Ca)	IS-3025(P-40)	12.0	mg/l	75	200
Iron (as Fe)	IS-3025(Part-53)	<0.05	mg/l	0.3	1
Nitrate (as NO ₃)	IS-3025(P-34)	<1.0	mg/l	45	No Relaxation
Total Dissolved Solid	IS-3025(Part-16)	95.0	mg/l	500	2000
Alkalinity (as Ca CO ₃)	IS-3025(P-23)	12.8	mg/l	200	600
Fluoride (as F)	APHA 22nd edit	<0.1	mg/l	1.0	1.5
Sulphate (as SO ₄)	IS-3025(P-24)	5.8	mg/l	250	400
Magnesium (as Mg)	IS-3025(P-46)	1.24	mg/l	30	100

CHECKED BY

AUTHORIZED SIGNATORY

This report is valid only for the samples tested in our laboratory. 2. Samples will destroyed after 30 days from the date of issue of the test report as specified. 3. Any complaints about this report should be communicated in writing within 7 days of the report. 4. It is the responsibility of the client to provide accurate information.

S. T. Dhande
Principal
St. Paul's School
Phase-VI, H-Block
Aya Nagar, New Delhi-110047

J. B. Bhatnagar
CHAIRMAN
ST. PAUL'S SCHOOL
Phase-VI, H-Block
Aya Nagar, New Delhi



ITS LABORATORY

Laboratory: A-01, Sector-40, Phase-2, Noida, Guram Dutt Nagar-201305 (U.P)
M: 099-11659600, 9306780312, 09958849764, 07210088624
Website: www.itslab.in; Email: contact@itslab.in, info@itslab.in, itslabs@gmail.com
An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory.

Report Code: W-270822-03 Page 2 of 2

SENSORY REQUIREMENT

RESULTS

No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1	Colour	IS:3025(Part-5)	Agreeable	Should be agreeable
2	Taste	IS:3025(Part-8)	Agreeable	Should be agreeable

MICROBIOLOGICAL REQUIREMENT

RESULTS

No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1	Escherichia coli	IS-1622	Absent	Absent/100ml
2	Coliform Bacteria	IS-1622	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meet as per IS-10500:2012 in acceptable limit. Water is fit for Drinking Purpose.

CHECKED BY

AUTHORIZED SIGNATORY



Principal
St. Paul's
Phase-VI
Ava Nagar

CHAIRMAN
ST. PAUL'S SCHOOL
Phase-VI, H Block
Aya Nagar, New Delhi-110027

1. Only for the samples tested in our Laboratory. 2. Samples will be destroyed after 30 days from the date of issue of the test report. 3. Any complaints about this report should be communicated in writing within 7 days of the report. 4. The report should be stored in a safe place.